



P.B.X.: 2575631, 2575632, 2577952, 2577921,
2577923, 2571479, 2571872, 2315967
Fax : (0253) 2577936

NASHIK MUNICIPAL CORPORATION, NASHIK

Rajiv Gandhi Bhavan, Sharanpur Road, (Post Box No.12) NASHIK - 422 002.

Visit us at : www.nashikcorporation.in E-mail : nashikcorporation@nashikcorporation.in

Visit us at : www.nashikcorporation.in E-mail : nashikcorporation@nashikcorporation.in

FIRE & EMERGENCY SERVICE

NMC / FIRE / WS / 92 / 2023

DATE - 30 / 04 / 2024

APPENDIX-XII

FIRE SAFETY CERTIFICATE

Certified that the **Guru Gobind Singh Public School and Junior College, Nashik at Khalsa Educational Complex, Wadala Pathardi Road, Indiranagar Annex, Nashik** comprised of **Ground Floor and three upper floor** owned / occupied by **Guru Gobind Singh Foundation, Nashik** have complied with the fire prevention and fire safety requirements in accordance with rule of Maharashtra Fire Service 3 (13) Rules, and verified by the officers concerned of Fire Service on 30 / 04 / 2024 in the presence of Concerned Principal and that the building / premises is fit for occupancy up to classes 12th. With effect from 2024 for a period of 1 year in accordance with rule and subject to compliance of specific conditions.

Form "B" - Ajinkya Fire Protection Services

Date - 01/01/2024

Issued on 30/04/2024 at

Nashik Fire Safety Certificate

One Year Valid



Signature with Seal :

Name :

Designation :

Name & Address of
Department / Office :

P.B. Pardeshi
30/04/2024

P.B. Pardeshi

For Chief Fire Officer

Rajiv Gandhi Bhavan,
Sharanpur Road, P.B. No. 12,
Nashik - 422001

Prescribed NOC is enclosed

To,

Guru Gobind Singh Public School and Junior College, Nashik
Khalsa Educational Complex,
Wadala Pathardi Road,
Indiranagar Annex,
Indiranagar,
Nashik

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

..... (Reasons to be recorded)



NASHIK MUNICIPAL CORPORATION

FIRE & EMERGENCY SERVICE

E mail :- cfo@nashikcorporation.in

Office of the Chief Fire Officer

Ref. No: NMC / FIRE / WS / Edu - 12 / 2020;

DATE: 12 / 03 / 2020

To,

M/s. Chairman; Guru Govindsing Foundation Trust,
C/o Shri. Shri. Prafulla G. Karkhanis, Architect, Nashik

Sub:- NOC under Maharashtra Fire Prevention & Life safety Measures Act, 2006, for Completion / Occupancy certificate for Educational (School) Occupancy Building in S. No. 98/1/2 To 2AB+3+4AB+5+6B+7AB+8/1, Wadala shiwar, Nashik.


- Ref:** i) This office Provisional letter no. NMC/FIRE/WS/II/Edu - 10/2017, dated - 29 / 01 / 2018,
ii) Town Planning Department NMC, commencement certificate No. LND/BP/A4/359/15368, dated - 08/02/2018
iii) Fire Prevention Fund Rs. 13,10,262/- (Fire Fund Rs. 12,47,520/- + Inspection Fee Rs. 62,742/-)
1. Rs. 6,68,010/- Paid wide Book No. 06376, Pass No. 59 & 60, Dt. 08/ 11 / 2012,
2. Rs. 6,42,252/- Paid wide Book No.05312, Pass No. 31, Dt. 24/ 01 / 2018.
iv) Inspection of system installed in building on date 09/03/2020.
v) This NOC is for building 1. Polytechnic College, 2. School Building, 3. Engineering College + Seminar Hall.

With ref. to above-mentioned subject, the representative of this department visited the said premises for Educational (School) Occupancy Building in S. No. 98/1/2 To 2AB+3+4AB+5+6B+7AB+8/1, Wadala shiwar, Nashik in presence M/s. Chairman, Guru Govindsing Foundation Trust, Nashik. for inspection of Fire prevention & protection arrangements provided by you. The Fire protection system, (wiz Hose reel system / Wet Riser / Down Comer / Automatic Fire Detection & Alarm system / Underground Tank / Terrace Tank / Fire Pump) installed are found in satisfactory working condition.

- 1) The fire protection systems installed in the building should be maintained in high efficiency state and in the proper working condition at all time during the use of the building by owner or occupier.
- 2) Staircases and Escape routes should be kept free of obstructions.
- 3) Side marginal open space from all sides of building should be kept open, free of obstructions & motor able. It shall be hard enough to take load of 40 ton Fire Appliance.
- 4) Fire protection system provided in the building should not be tempered / altered or removed from the building for any reason without permission of this department.
- 5) It will be the sole responsibility of the OWNER / OCCUPIER to submit every six months i.e. in January and July, a certificate in the prescribed form issued by a Licensed agency, approved by Chief Fire Officer, NMC regarding the compliance of the Fire Prevention and Life Safety Measures in the building under clause 3(3) of Maharashtra Fire Prevention and Life Safety Measures Act 2006.
- 6) On contravention of any of above conditions, action will be taken against the owner/occupier and / or builder under Maharashtra Fire Prevention and Life Safety Measures Act 2006, clause 3, 4, 8 & 36 and this N.O.C. will stand cancelled without any notice and the owner / occupier and / or the builder will be solely responsible to loss of life or property, if any.
- 7) The undersigned reserves rights to amend any additional recommendations deemed fit during the inspections due to statutory provisions amended from time to time and interest of the protection of life and property.
- 8) This certificate is issued on the basis of approved drawings and commencement certificate issued by Town Planning Department NMC under ref.no.2 & the equipments shown on site and information submitted in written by the owner and/or builder of the building. The owner and / or builder of the building & Licensed agency which carried out the Fire protection work of the building will be solely responsible for any false information.

- NOTE:-** 1) The Licensed Agency which has installed the Fire Protection system will be responsible for servicing & maintenance of the system for next five years and to issue the 'Form B' certificate as per clause (6) above.
- 2) This NOC is given only for Active Fire Protection System i.e. for actual fire protection installations such as Down comer etc. and not for Passive Fire Protection e.g. Alternate staircase, Fire lift, Generator etc.
- 3) Fire brigade officials will not be responsible for any accident due to lack of Passive Fire Protection System. The Architect / Engineer, owner and / or builder and Licensed agency which carried out the Fire protection work of the building will be fully responsible for the same.

Copy to:
ADTP / Executive Engineer,
Town Planning Deptt., NMC




Chief Fire Officer,
Nashik Municipal Corporation.

Year
1) 2021
2022


Renewal on Form B
Ajinkya Fire Protection
Services
Dated - 15/7/2022

Annual Fee Rs. 28565/- Received
Book No 853 Pass No 05 Date 23/05/2022


Chief Fire Officer
Nashik Municipal Corporation

2) 2023


Ajinkya Fire Protection Annual Fee Rs. 13103/-
Services Book No 859
" Form B " Pass No 98
Date: 18-01-2023 Date: 31/02/2023


Chief Fire Officer
Nashik Municipal Corporation

3) 2024

Ajinkya Fire Protection
Services
" Form B "
Date: 01-01-2024

वार्षिक फी र.रु. 13103 /-
बुक नं. 2555 पास नं. 17 दि. 29/04/2024
अन्वये वसूल


P.B. Pardeshi
30/04/2024
मुख्य अग्निशमन अधिकारी
नाशिक महानगरपालिका, नाशिक

"बी" फॉर्मची नोंद घेतली.